



Nota:

- Platbanda de otel zincat si electrozii de otel zincat se vor ingropa la adancimea de 0.7m;
- Daca nu se realizeaza rezistenta de dispersie de max. 4 ohmi se vor mai adauga electrozi de otel zincat pana se obtine valoarea de maxim 4 ohmi;
- Dimensiunile cabinei sunt functie de producator si nu se cunosc.

3				6			
2				5			
1				4			
Rev.	Descriere	Data	Semnat	Rev.	Descriere	Data	Semnat
Acest document este proprietatea S.C. ELLIS'92 S.R.L. si nu va fi comunicat fara autorizare							
Intocmit	Verificat	Aprobat	Beneficiar		Denumire proiect		
Stefanica Oana	Stefanica Victor	Ionescu Androne	CONPET S.A. PLOIESTI		DEZAFECTAREA REZERVORULUI R9 TITEI (V=2889 mc) CONSTRUCTIE REZERVOR NOU PENTRU TITEI (V=2500 mc) STATIA DE POMPARE CARTOJANI		
 arhitectura proiectare inginerie consultanta tehnica		 CERTIFICATE CONFORM ISO 9001		Legare la pamant Cabina SPC		Nr.: A614-PC-08	
						Scara:	
						Index: A614-PC-BD	
						Rev.0	
Material:		Masa: kg		Data: 06.2017		Plansa:	