






TRASEU CONDUCTA

MATERIALE FOLOSITE

CANTITATI

<b>MATERIAL CONDUCTA</b> Teava sudata longitudinal Ø273.1 x 7.1mm, L 360N, PSL 2 conf. SR EN ISO 3183:2013 - teava preizolata cu PE, tip N - v conf. DIN 30670 cu grosimea de 2,8 mm conf. SR EN ISO 21809-1:2011; - mansoane termocontractile tip C50L la imbinari conf. SR EN 12068:2002	<i>Lungime reala conducta Ø10 3/4" proiectata L= 582.00m, din care: 579.00 m cd. izolata cu PE 3.00 m cd. pentru curbe</i>		
<b>TRAVERSARI APE, DRUMURI, CF IN TUB PROTECTOR</b>			
<b>SCHIMBARI DE DIRECTIE CU CURBE</b> Teava CMF Ø273.1 x 8.8mm, 5DN, L 360N	<i>Lungime teava pentru curbe L= 3.00m</i>		
in plan orizontal	stanga	1 x 30° (pich. 27)	1 x 10° (pich. 28)
	dreapta		
in plan vertical	urcare		
	coborare		
<b>PRESETUPE</b>			
<b>INELE DISTANTIERE</b>			
<b>PROTECTIE CATODICA</b>	 conducta veche      conducta noua	priza de potential cu anozii, la cuplare pichet nr. 1	priza de potential cu anozii, la cuplare pichet nr. 28
			 conducta noua      conducta veche
<b>LUCRARI SI INSTALATII AUXILIARE</b>			
<b>CLASA DE SUDURA</b>	clasa I-a de calitate a imbinarilor sudate conform SR EN 14163:2004; control cu R.P. : 100% sudurile de pozitie, cuplari; in fir curent 25%		
<b>SAPATURA</b>	sapatura mecanizata 90%, sapatura manuala 10%, adancime sant 1.17 m, latime sant 0.90 m in fir continuu		
<b>CULOAR DE LUCRU</b>	11.00 m		
<b>PROBE PRESIUNE</b>	1) proba de rezistenta cu apa la 80 bar timp de min. 1 ora; 2) proba de etanseitate finala cu apa la 70.4 bar timp de min. 8 ore.		
<b>ARMATURI</b> Flanse, robineti si elemente electroizolante	Flansa cu gat PN 64, DN 250 - 2 buc. in pichet nr. 1, 28		
<b>BORNE SCHIMBARE DIRECTIE</b>	 La cuplare (pichet 1)	 pichet 27	 La cuplare (pichet 28)

Verificator/ Expert	Nume	Semnatura	Cerinta	Referat / Expertiza Nr. / Data	
S.C. SNIF PROIECT S.A. Targoviste Numar de inmatriculare J15/925/2005			Beneficiar: CONPET S.A. PLOIESTI		Pr. nr. 345/2017
Specificatie	Nume	Semnatura	Scara:	"Inlocuire tronson de conducta de titei Ø 10 3/4" F1 Barbatesti-Orlesti in zona Becsani - mal drept rau Cerna, comuna Fartatesti, jud. Valcea 500m de la gradina Suvar - V.S. mal drept rau Cerna"	Faza PT+CS+D
Sef proiect	Ing. Costea Paul				
Desenat	Ing. Radu Florin		Data: 2017	SCHEMA DE MONTAJ CONDUCTA Ø10 3/4"	Pl. nr. 15
Proiectat	Ing. Costea Paul				