


Nota:

- Platbanda de otel zincat si electrozii de otel zincat se vor ingropa la adancimea de 0.7m;
- Daca nu se realizeaza rezistenta de dispersie de max. 4 ohmi se vor mai adauga electrozi de otel zincat pana se obtine valoarea de maxim 4 ohmi;
- Dimensiunile cabinei sunt functie de producator si nu se cunosc.

REV.	DESCRIERE	19.09.2018	STEFANICA OANA	STEFANICA VICTOR	STEFANICA VICTOR
		DATA	PROIECTAT	VERIFICAT	APROBAT
S.C.CONPET S.A. STR. 1848, NR. 1 – 3 PLOIESTI, ROMANIA 		DENUMIRE PROIECT:			
		Construcție rezervor nou pentru titei (V=2500 mc) Statia de Pompare Poiana Lacului			
		DENUMIRE DESEN:			
		Legare la pamant Cabina SPC			
NUMAR DESEN.:		PC-08			SCARA:
FISIER:		PC08-DWG			FILA: 1/1