

 CONPET BIROU INSPECTIA CALITATII	RAPORT DE INCERCARE NR.1208	Data: 23.10.2019
--	--	-------------------------

Proba: **Șlam eșantionat din R1 Marghita**

Tip proba: proba prelevata de operator Rampa Marghita

Data esantionare proba:

Data finalizare incercari: 23.10.2019

NR.	CARACTERISTICA	U.M.	VALOARE		Metoda de incercare
			Prevazuta	Determinata	
1	Aspect			semifluid	
2	Densitate/20°C	kg/m ³		870.6	SR EN ISO 3838
3	Punct inflamare	°C		83	SR 5489
4	Continut apa	%m/m		6.5	SR EN ISO 9029
5	Continut sediment	%m/m		1.88	SR EN ISO 3735
6	Continut sulf	%m/m		0.45	ASTM D 4294-8
7	Continut hidrocarburi	%m/m		89	SR EN ISO 3405

Concluzii: Deseu cod 050103*



Raportul se refera numai la proba de incercat precizata

FC-60-42 Ed.3