



- Placa de conexiuni va fi fixata de cutia prizei cu suruburi si distantiere;
- Cablurile vor fi fixate in borne prin alamire. Numarul cablurilor conectate in priza de de potential va fi de 2 sau 3 (1 sau 2 de la electrozi si unul catre rezervor);
- Toate cablurile (poz. 7) atat cele de la electrozi cat si cel catre rezervor vor fi de tip Cyy 1x6 mm².

Pos	Name	Standard/Drawing	Pcs	Material	Obs.
			08.06.2019	STEFANICA OANA	STEFANICA VICTOR
REV.	DESCRIERE		DATA	PROIECTAT	VERIFICAT
					APROBAT



FILA:
1/