


- Nota:
- Platbanda de otel zincat si electrozii de otel zincat se vor ingropa la adancimea de 0.7m;
 - Daca nu se realizeaza rezistenta de dispersie de max. 4 ohmi se vor mai adauga electrozi de otel zincat pana se obtine valoarea de maxim 4 ohmi;
 - Dimensiunile cabinei sunt functie de producator si nu se cunosc.

		25.10.2018	STEFANICA OANA	STEFANICA VICTOR	STEFANICA VICTOR
REV.	DESCRIERE	DATA	PROIECTAT	VERIFICAT	APROBAT
S.C.CONPET S.A. STR. 1848, NR. 1 – 3 PLOIESTI, ROMANIA 	DENUMIRE PROIECT:				
	Construcie rezervoare pentru titei R1 si R2 V=2500 mc Statia de Pompare Moreni, Dambovita				
	DENUMIRE DESEN:				
	Legare la pamant Cabina SPC				
NUMAR DESEN.:		PC-08			SCARA:
FISIER:		PC08-DWG			FILA: 1/1