

- ANEXA 2 -

CONTROALE / VERIFICARI IMBINARI SUDATE REZERVOR R4 - STATIA BAICOI, CONFORM SR EN 14015:2005

COMPONENTA	TIP SUDURI	TIP CONTROL	VOLUM	STANDARD REFERINTA	CRITERII DE ACCEPTARE
Fund					Conform SR EN14015 :2005
- panou central	Suduri de colt	Vizual (VT)	100%	SR EN ISO 17637 :2011	
		Lichide penetrante (PT)	100%	SR EN ISO 3452-1 :2003	
		Perna de vacuum -	100%	SR EN 1593 :2002+A1 :2004	
- inel periferic	Imbinari sudate radiale	Vizual (VT)	100%	SR EN ISO 17637 :2011	
		Lichide penetrante (PT)	100%	SR EN ISO 3452-1 :2003	
	Suduri de colt (imbinare inel cornier-manta, inel cornier-inel periferic)	Vizual (VT)	100%	SR EN ISO 17637 :2011	
		Lichide penetrante (PT)	100%	SR EN ISO 3452-1 :2003	

NOTA

Prezenta Anexa insoteste documentul A572U-PCC2 si se va citi impreuna cu acesta.