



BILL OF MATERIALS			
ID	QTY	ND	DESCRIPTION
1	4.2M	250	TEAVA FARA SUDURA, P235TR2, EN 10216-5, ϕ 273x8
2	25.8M	100	TEAVA FARA SUDURA, P235TR2, EN 10216-5, ϕ 114.3x5.6
3	2	250	COT 90°, 3D, P235TR2, EN 10253-2, ϕ 273x8
4	6	100	COT 90°, 3D, P235TR2, EN 10253-2, ϕ 114.3x5.6
5	1	250	TEU EGAL, P235TR2, SR EN 10253-2, ϕ 273x8
6	5	100	FLANSA CU GAT, P235GH, Tip11, B1, PN16, SR EN 1092-1
7	1	100	FLANSA OARBA, P235GH, Tip05, B1, PN16, SR EN 1092-1
8	40	M16X85	PREZON FILETAT+2 PIULITE, 21CrMoV5-7/25CrMo4
9	5	100	GARNITURA SPIROMETALICA, PN16, B1, Tip GS/E, Gr 4,7
10	2	100	ROBINET SERTAR PANA, PN16, B1, EN 1074-1

00	09.09.2022		Emis pentru comentarii
Rev.	Data	Modificare ceruta de:	Descriere modificare
Verificator/ Expert	Nume/ Name	Semnatura/ Signature	Cerinta/ Requirement
Proiectant general/General Designer		Referat/ Expertiza Nr./ Data/ Reference/ Expertise No./ Date	
ROENGG CONSULTING SRL		Beneficiar / Client :	
RO 24611389 / 0344 806 979 / contact@roengg.com		S.C. CONPET S.A.	
Proiectant de specialitate/ Specialist Designer		Titlul proiectului / Project Title :	
		PROIECTARE REZERVOR PENTRU APA P.S.I. SI PROIECTARE INEL DE RACIRE LA REZERVPRUL R1 PENTRU TITEI - DEPOZIT TAMPON INDEPENDENTA	
		Titlul plansei / Drawing Title :	
		SCHEMA IZOMETRICA 100-FOW-002-P235TR2 / 100-FOW-004-P235TR2 / 250-FOW-003-P235TR2	
Proiectat / Designed	A.M.	Scara / Scale :	Nr. Desen / Drawing No.
Verificat / Checked	R.M.	Data / Date :	Faza / Project Phase:
Aprobat / Approved	S.D.	09.09.2022	DTDS
		10532021-RNG-DTDS-PIP-ISO-001_00_RO	Nr.pag. / Page No: 4/9