




A — A



NOTA :

Detaliul este valabil si in cazul montarii altui numar de anodi, amplasarea lor pastrand distanta de 3 m unul fata de altul;

4	Anod galvanic	-	4	zinc 99.99%	-	-			
3	Folie avertizoare	-	-	PVC	-	-			
2	Priza de potential	-	1	-	Tip CONPET	-			
1	Cablu CYY	-	-	cupru	1 x 25 mm²	-			
Poz.	DENUMIRE		Nr. desen sau STAS	BUC	MATERIAL	OBSERVATII	MASA kg/buc		
1	02.2023	Caiet de sarcini nr. 5862 / 15.02.2022	Documentatie spre avizare		Victor DINITA	Liviu ANDREI	Antonio TACHE		
0	11.2022	Caiet de sarcini nr. 5862 / 15.02.2022	Documentatie spre avizare		Victor DINITA	Liviu ANDREI	Antonio TACHE		
REVIZIA	DATA	DESCRIEREA REVIZIEI			REVIZUIT	VERIFICAT	APROBAT		
MATERIAL -			MASA NETA -		SCARA PLAN N/A		DATA 11.2022	Nr. Proiect CON-006 2022	
Masurat	Victor DINITA	INLOCUIRE COLECTOARE SI ROBINETI PUNCT DE LUCRU CONPET S.A. – DEPOZIT OIL TERMINAL CONSTANTA						Faze proiect P.T.	
Desenat	Victor DINITA								
Verificat	Liviu ANDREI								
Aprobat	Antonio TACHE								
									
DETALIU MONTAJ GRUP ANOZI									
CON-006-2022-38								PLANSA 1/1	FORMAT A4

Acesta este desen CAD si nu va fi modificat manual

